

EMS — Energy Monitoring System: measurements, solar PV, storage and cost optimisation

[Czytaj po polsku](#)

EMS in practice: from measurements to informed decisions. A guide for property managers, businesses, municipalities and technical teams. It explains Energy Monitoring System design, data interpretation and integration with PV, storage and automation. This describes deployment options and principles; it does not imply that every control function is already commissioned at a customer site.

[Explore EMS from Opomiarowani by DATPOL](#)

Contents

1. [What is an EMS and how does it change daily work?](#)
2. [Who benefits: from individual premises to industrial and municipal sites](#)
3. [What we measure: kW is not kWh](#)
4. [Solar PV: see how much generation stays on site](#)
5. [Battery storage: more than charging at the lowest price](#)
6. [Dynamic prices: evaluate the whole decision](#)
7. [Demand peaks, contracted capacity and reactive energy](#)
8. [Hydrogen: monitoring the conversion chain](#)
9. [Architecture: from meter to a trustworthy report](#)
10. [Alerts, cybersecurity and control governance](#)
11. [Where monitoring supports obligations and audits](#)
12. [Specialist installations and billing need appropriate equipment](#)
13. [How to evaluate savings realistically](#)

1. What is an EMS and how does it change daily work?

An Energy Monitoring System collects data about consumption, generation and energy flows. Instead of reviewing bills, inverter applications and meter readings separately, you gain a shared view of the site.

Opomiarowani scopes range from readings and reports to agreed automation integration. Energy Management System describes wider management, potentially including control rules. Control functions are commissioned separately after equipment, process constraints and permissions have been checked. This service describes deployment options, not an identical feature set available at every site.

2. Who benefits: from individual premises to industrial and municipal sites

The greatest value comes when data informs an available decision. A factory can assess energy per shift or unit produced. A water utility can compare kWh per cubic metre pumped. Hotels can relate use to occupancy, and office managers to opening hours. Cold stores, farms and shops can analyse continuously operating equipment. Municipalities can compare schools, offices, sports facilities and lighting. Access is scoped to responsibilities; tenant energy statements can be linked with Podlicznik.

3. What we measure: kW is not kWh

kW describes instantaneous or interval-average power; kWh is energy used over time. We record import and export, active power and, with suitable analysers, reactive and apparent power, power factor, voltage, current and phase parameters. Data helps identify demand peaks, imbalance and deviations to investigate. Power-quality analysis, such as harmonics, requires appropriate instruments and recording settings. A basic kWh meter cannot

replace a power-quality analyser. Gas, heat, water and environmental readings can extend the picture.

4. Solar PV: see how much generation stays on site

PV generation alone does not show the full benefit. Inverter data is combined with supply-point and load measurements to separate on-site use, import and export. Self-consumption measures how much generation is used locally; self-sufficiency measures how much demand is met locally. With storage, flow directions must be considered to prevent double counting. Reports can identify loads suitable for moving into production periods, such as vehicle charging, hot-water preparation or permitted process cycles. Process reserves and user comfort remain overriding constraints.

5. Battery storage: more than charging at the lowest price

Depending on BMS and inverter interfaces, we analyse state of charge, available power, energy flows, temperature and limitation signals. A strategy may combine greater self-consumption, reduced demand peaks and a backup reserve. Nominal and usable capacity must be distinguished, with efficiency, charging power, SOC limits and warranty conditions included. An EMS cannot create backup capability if the electrical arrangement and inverter do not provide it. Control commands must respect the BMS, manufacturer protections and critical-load priorities.

6. Dynamic prices: evaluate the whole decision

The market price is only one part of the calculation. We assess the actual contract formula, supplier margin, variable charges, export rules and settlement intervals. Storage adds losses and battery wear costs. A negative market price does not automatically mean a negative bill. Planning may use PV and load forecasts and available prices, but forecasts remain distinct from measurements. Automatic load shifting or charging requires accessible interfaces, approved rules and defined behaviour when prices or connectivity are unavailable. Without control, the

system can still provide recommendations and scenario comparisons.

7. Demand peaks, contracted capacity and reactive energy

Simultaneous starts of large loads can create a peak hidden in monthly kWh totals. We analyse load over the intervals relevant to the contract and identify possible equipment sequencing. Peak reduction is useful where the process, storage and billing arrangements allow it. Reactive-energy recording helps assess charges and the need for a compensation study. An EMS does not itself compensate reactive power. Compensation equipment requires assessment of loads, harmonics and installation conditions. Not every instantaneous rise creates a billable exceedance.

8. Hydrogen: monitoring the conversion chain

A hydrogen project benefits from comparing electrolyser input, auxiliaries and compressor use, hydrogen production and energy recovered through a fuel cell. kWh/kg, operating time, availability and conversion losses can be assessed where the installation exposes suitable data. Tank pressure alone is insufficient for an accurate inventory without a model accounting for temperature and gas properties. Hydrogen integration is individually scoped with the designer and technology supplier. An EMS may receive status signals but does not replace hydrogen detection, ventilation, safety interlocks or safety controllers.

9. Architecture: from meter to a trustworthy report

Compatible sources are connected through Modbus RTU/TCP, pulses, documented APIs and MQTT. LoRaWAN can support periodic readings from dispersed points; it is not the basis for fast control loops or safety functions. Each point needs units, scaling, flow direction, timestamps and quality information. Cumulative kWh readings are differenced over time; power is integrated only with adequate sample quality. Meter replacement, resets, gaps and delayed data must be handled. Local buffering and history recovery depend on equipment and the agreed

10. Alerts, cybersecurity and control governance

Useful rules include after-hours consumption, communication loss, reversed energy flow, balance deviations and equipment limitations. Thresholds, delays and recipients follow the process. Integration starts with read access; writes require separate permissions, an allowed-command list and acceptance tests. Design can include OT/IT segmentation, encrypted channels, action logs, least privilege and update procedures. Cloud failure must not remove local protection. Public access to inverter or BMS control registers is not part of the design.

11. Where monitoring supports obligations and audits

There is no universal requirement for every business with PV to buy an EMS. Duties depend on the organisation, energy use, property and project conditions. Measurements support energy audits and investment evaluation. ISO 50001 also covers responsibilities, objectives and improvement; a dashboard does not establish certification. Article 11 of EU Directive 2023/1791 distinguishes above 85 TJ for an energy management system and above 10 TJ for audits, using three-year average annual consumption across all energy carriers. These are EU-level provisions; applicability, deadlines and Polish implementing law require organisation-specific checking. This English version describes the Polish service context, not UK compliance. Sources appear below.

12. Specialist installations and billing need appropriate equipment

Hydrogen requires a separate hazard assessment, suitable equipment for classified areas and review of pressure-equipment and inspection requirements. A process-system reading does not replace required protections. Likewise, energy monitoring does not replace the operator's settlement meter; billing use requires

checking applicable metrological requirements. Connection conditions, export limits, funding terms or contracts may impose further recording duties. The proposal distinguishes operational indications from measurements intended for documentation or settlement.

13. How to evaluate savings realistically

First establish a baseline: use, cost, working hours, production, weather and site changes. After deployment, compare equivalent conditions rather than merely two bills. Lower kWh may reflect reduced production rather than improved efficiency. Assess integration and support costs, storage losses and equipment life. Useful indicators include kWh/m², kWh per production unit, period cost, overnight demand and the local-energy share. An EMS helps identify and measure improvements; it does not guarantee a savings percentage without data analysis.

14. Phased deployment: measurement, decisions, automation

1. Inventory meters, PV, storage, tariffs and loads. 2. Design measurement points and secure communication. 3. Commission readings and compare them with equipment. 4. Establish a baseline, indicators and alerts. 5. Evaluate operational changes and their economics. 6. Add optional control after agreeing priorities, limits and tests. 7. Review outcomes and maintain the system. For an initial discussion, provide bills and a load profile, inverter and storage models, an installation diagram and working hours. DATPOL will scope integration and quote for the particular site.

15. Terms and basic calculations

Quantity	Meaning	Check
kW / kWh	Power / energy over time.	Do not compare instantaneous power with monthly consumption.

Quantity	Meaning	Check
kvar / kvarh	Reactive power / reactive energy.	Check direction, signs and contractual charges.
SOC / SOH	State of charge / estimated battery health.	SOH depends on the manufacturer's method; it is not a direct remaining-runtime measurement.
PPE	Polish supply-point identifier.	The measurement boundary must match the meters included in reconciliation.
Self-consumption	Share of local generation used on site.	Distinguish direct use from energy passing through storage.
Self-sufficiency	Share of demand met locally.	This uses a different denominator from self-consumption.
Round-trip efficiency	Energy discharged / energy charged.	Use the same AC or DC boundary and account for auxiliaries.

Example without storage: PV generates 100 kWh, with 60 kWh used locally and 40 kWh exported. Self-consumption is 60%. If total site demand is 150 kWh, self-sufficiency is 40%. Zero generation or demand makes the corresponding percentage undefined; do not divide by zero.

Energy increment: closing minus opening register, with the verified ratio and unit applied. A falling cumulative register needs reset or replacement checks. A constant 10 kW over 30 minutes represents 5 kWh. Variable power requires integration or properly sampled data.

16. Storage economics example

Illustrative assumptions: purchase 100 kWh at a full variable import cost of PLN 0.40/kWh; at 90% round-trip efficiency, use the discharged 90 kWh instead of imports at PLN 0.90/kWh. Avoided expenditure is PLN 81 and charging cost PLN 40. Deduct an illustrative PLN 5 wear allowance: the cycle contribution is PLN 36. Investment, fixed charges and taxes are excluded. This is not a price forecast or a return guarantee. Where the energy could have been sold, include the opportunity cost of forgone exports.

17. What should each measurement point contain?

- Unique identifier, site, circuit and organisation assignment.
- Device model, register/protocol, unit, multiplier and flow direction.
- Measurement and receipt timestamps, time zone and daylight-saving handling.
- Quality status: valid, stale, missing, estimated or error.

- Raw and converted values and configuration-change history.
- Retention, export, backup and access rules; personal data should not appear in public identifiers.

Do not add the main meter and its submeters as separate costs for the same property. Align period boundaries and check completeness before comparing data. Inverter power, meter energy and model forecasts are different data types.

18. Commissioning checklist

1. Compare system values with the device; verify scaling, signs and units.
2. Confirm balance topology, assignments and absence of double counting.
3. Check timestamps, gaps, meter resets and reconnection under controlled conditions.
4. Test an alert and confirm recipient, threshold, delay and message rate limits.
5. Check account isolation and export of only the correct organisation's data.
6. Compare the first report with readings and relevant invoice components.
7. Where control is included, accept it separately: limits, priorities, manual override and connectivity loss.
Tests must not impair process protection.
8. Record responsibilities, contacts, change procedures and maintenance plans.

19. Common issues and initial checks

Symptom	Check
Consumption is several times too high.	W versus kW, Wh versus kWh, transformer ratios and duplicate scaling.
The balance does not reconcile.	Time boundaries, common areas, flow directions, missing points and storage.
The chart shows zero after a fault.	Whether missing data was incorrectly converted to zero.
Storage differs from the plan.	BMS limits, SOC reserve, inverter schedules, temperature and write permissions.
Cost differs from the invoice.	Net/gross, fixed charges, distribution, period, rates and data completeness.
Too many alerts.	Process profile, hysteresis, exceedance duration, aggregation and recipients.

Do not change BMS protection, protective settings or wiring to make a result fit. Report the device model, measurement point, event time and expected result. Never send passwords or tokens.

20. Questions and answers

Does an EMS automatically control every battery?

No. It requires a compatible interface, control authorisation and a design respecting the BMS, warranty and installation limits. Monitoring can be the first stage.

Do dynamic prices always reduce the bill?

No. Results depend on the load profile, contract, charges and ability to shift demand. An EMS allows scenarios to be compared using data.

Can equipment from different manufacturers be integrated?

We assess models, protocols, data access and permissions. Integration is confirmed after checking, separately for reading and control.

21. Sources and currency

References checked on 6 October 2026. At deployment, review current legislation, amendments, contracts and equipment documentation. This guide does not replace a site-specific assessment.

- [URE — dynamic-price contracts](#)
- [EUR-Lex — Energy Efficiency Directive, Article 11](#)
- [Polish Energy Efficiency Act — consolidated text](#)
- [ISO 50001 — energy management](#)
- [UDT — hydrogen storage and tanks](#)

Related guides

- [Podlicznik — meter readings, tenant charges and reports: a property manager's guide](#)
- [What to prepare before connecting a public authority to a SOC](#)
- [How to prepare a business for an audit without disrupting operations](#)

Choose your next guide

- [Opomiarowani — sensors, alerts and measurement history explained](#)
- [EMS for local authorities — energy across schools, offices and municipal sites](#)
- [EMS for businesses — from consumption profiles to an improvement plan](#)
- [Podlicznik — meter readings, tenant charges and reports: a property manager's guide](#)

Plan your installation with DATPOL

[View the service and implementation scope](#) · biuro@datpol.com · [+48 55 621 29 29](tel:+48556212929)

Updated 13 October 2026. Features are agreed for each installation.

Revision #3

Created 2026-10-06 16:26:58 UTC by Administrator DATPOL

Updated 2026-10-13 11:19:30 UTC by Administrator DATPOL